

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VC045		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SCHMOLL, DALE						Phone # (920)606-7445		1. Well Location				Fire # (if avail.)									
Mailing Address W4004 KROPP RD						Town of BLACK CREEK						W4004									
City BLACK CREEK						State WI		Zip Code 54106				Street Address or Road Name and Number W4004 KROPP RD									
County Outagamie		Co. Permit #		Notification # 48782661		Completed 08-08-2013		Subdivision Name BLACK CREEK				Lot # Block #									
Well Constructor (Business Name) THOMAS A SCHMIDT						Lic. # 3966		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.4737 °N -88.388 °W		Method Code GCD013							
Address SCHMIDTS WELL DRILLING BLACK CREEK WI 54106-9803						Well Plan Approval #		SW SW Section Township Range or Govt Lot # 12 23 N 17 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
Approval Date (mm-dd-yyyy)						Hicap Permanent Well #		Common Well #						Specific Capacity 0.1							
Hicap Property ? No						Hicap Potable ?		Hicap Well ? No						Heat Exchange ___ # of drillholes							
3. Well serves 1 # of Private, potable														Hicap Property ? No		Hicap Potable ?		Hicap Well ? No		Heat Exchange ___ # of drillholes	
4. Potential Contamination Sources - ON REVERSE SIDE														5. Drillhole Dimensions and Construction Method		8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		160		Yes Rotary - Mud Circulation Yes				Rotary - Air				R B C G CLAY & STONE		Surface		30			
6		160		180		Rotary - Air & Foam				Drill-Through Casing Hammer				G M L L LIMESTONE		30		130			
Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia				Removed? ___ depth ft. (If NO explain on back side)				T S N - SANDSTONE		130		180			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				18 in. above grade							
6		NEW BLACK STEEL WHEATLAND TEXAS PIPE 18.97 # ASTM A53 WELDED-PK DRIVE SHOE				Surface		162		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 100 ft. below surface				Disinfected ? Yes							
Pumping at 12 GP M for 1 Hrs.		Pumping Method ?				Capped ? Yes				Filled & Sealed Well(s) as needed? No											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method BRADENHEAD														13. Constructor / Supervisory Driller				Lic #		Date Signed	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		TAS				08-14-2013							
NEAT GROUT				Surface		160		40 S		Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		26	Septic or Holding, or POWTS Tank		104

Comment:

Created On: 11-04-2013

Updated On: 11-20-2019

Review Status: