Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VC045

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHMOLL, DALE	Phone #: (920)606-7445
Mailing Address: W4004 KROPP RD	
City: BLACK CREEK	State: WI — Zip Code: 54106
County: Outagamie	Co. Permit #:
Notification #: 48782661	Completed: 08-08-2013
Well Constructor (Business Name): THOMAS A SCHMIDT	Lic. #: 3966
Facility ID # (Public Wells):	
Address: SCHMIDTS WELL DRILLING BLACK CREEK WI 54106-9803	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.1	

1. Well Location

Town of BLACK CREEK	Fire # (if avail.): W4004
Street Address or Road Name and Number: W4004 KROPP RD	
Subdivision Name: BLACK CREEK	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.4737 °N -88.388 °W	Method Code: GCD013
SW SW or Govt Lot #	Section: 12 — Township: 23 N — Range: 17 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	160
6	160	180

Upper Enlarged Drillhole: Yes

Lower Open Bedrock: Yes

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	B	C	G	CLAY & STONE	Surface	30
G	M	L	L	LIMESTONE	30	130
T	S	N	-	SANDSTONE	130	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL WHEATLAND TEXAS PIPE 18.97 # ASTM A53 WELDED-PK DRIVE SHOE	Surface	162
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT GROUT	Surface	160	40 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAS		08-14-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		26	Septic or Holding, or POWTS Tank		104

Comment:

Created On: 11-04-2013 Updated On: 11-20-2019 Review Status: