

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VC047		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FURSTENBERG, MICHAEL						Phone # (920)419-7755		1. Well Location				Fire # (if avail.)			
Mailing Address N4148 LAIRD RD						Town of ELLINGTON						N4148			
City BLACK CREEK						State WI		Zip Code 54106				Street Address or Road Name and Number N4148 LAIRD RD			
County Outagamie		Co. Permit #		Notification # 48723292		Completed 07-31-2013		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) THOMAS A SCHMIDT				Lic. # 3966		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.38998 °N -88.5062 °W				Method Code GPS008	
Address SCHMIDTS WELL DRILLING BLACK CREEK WI 54106-9803				Well Plan Approval #		SW SE		Section 12		Township 22 N		Range 16 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2				2. Well Type New Well					
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No				of previous unique well # constructed in					
Heat Exchange ___ # of drillholes				Hicap Potable ?		Reason for replaced or reconstructed well ?				Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 130			Yes Rotary - Mud Circulation Yes												
6 130 160			Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T B S G				SAND & STONE				Surface		48					
G H G G				GRAVEL				48		52					
T H N -				LIGHT BROWN SANDSTONE				52		160					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW BLACK STEEL WHEATLAND TEXAS PIPE 18.97# ASTM A53 WELDED-PD DRIVE SHOE				Surface		131							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material										9. Static Water Level					
Method BRADENHEAD										12 ft. below ground surface					
Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement										11. Well Is					
NEAT GROUT CEMENT Surface 130 36 S										12 in. above grade					
Filled & Sealed Well(s) as needed?										Developed ? Yes					
13. Constructor / Supervisory Driller										Date Signed					
TAS										08-14-2013					
Drill Rig Operator										Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		53	Building Overhang		18
			Septic or Holding, or POWTS Tank		47

Comment:

Created On: 11-04-2013

Updated On: 02-09-2023

Review Status: