Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VE305

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STEINHAUS, JON			Phone #: (608)981-2534
Mailing Address: PO BOX 116			
City: BRIGGSVILLE	State: WI	Zip Code: 53920	
County: Columbia	Co. Permit #:	Notification #: 48501891	Completed: 06-13-2013

Well Constructor (Business Name): JAMES R PHILLIPS	Lic. #: 541	Facility ID # (Public Wells):	
Address: PHILLIPS WELL DRILLING INC GRAND MARSH WI 53936		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LEWISTON

Fire # (if avail.):

Street Address or Road Name and Number: N9468 CO AA

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 43.62282 °N -89.58595 °W
Method Code: GPS008

NE NE or Govt Lot #	Section: 7	Township: 13 N	Range: 8 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WELL IN PIT

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	63
1.25	63	66

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	30
-	-	C	-	CLAY	30	50
-	-	Y	-	SAND & GRAVEL	50	66

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND NEW STEEL ASTM53 ERW T&C 3.75#	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	STAINLESS POINT 60 GU.	63	66

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JP		07-01-2013
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		8
Septic or Holding, or POWTS Tank		32

Comment:

Created On: 08-21-2013 Updated On: 08-21-2013 Review Status: