

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VE310		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner POLK, RODNEY						Phone # (608)697-0942		1. Well Location				Fire # (if avail.)		
Mailing Address N4770 PINECREST DR						Town of MONTELLO						Street Address or Road Name and Number N4770 PINECREST DR		
City MONTELLO			State WI		Zip Code 53949			Subdivision Name			Lot #		Block #	
County Marquette		Co. Permit #		Notification # 48897033		Completed 08-12-2013		Latitude / Longitude in Decimal Degree (DD) 43.81257 °N -89.26608 °W			Method Code GPS008			
Well Constructor (Business Name) JAMES R PHILLIPS				Lic. # 541		Facility ID # (Public Wells)		SE NW Section Township Range or Govt Lot # 1 15 N 10 E		2. Well Type Replacement of previous unique well # LX014 constructed in 1997				
Address PHILLIPS WELL DRILLING INC GRAND MARSH WI 53936				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ? OLD WELL TO NEAR SEWAGE PIT						
Hicap Permanent Well #			Common Well #		Specific Capacity			Construction Type Jetted						
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock											
2 Surface 56			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
1.25 56 60														
8. Geology														
Dia. (in.) From (ft.) To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)					
2 Surface 56			- - Y -			SAND GRAVEL			Surface 60					
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is		
2		WHEATLAND NEW STEEL T&C ERW 3.75#				Surface		56		42 ft. below ground surface		16 in. above grade		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes		
1.25		STAINLESS POINT 60 GA.				56		60		Pumping level 42 ft. below surface		Disinfected ? Yes		
7. Grout or Other Sealing Material										Pumping at 10 GP for 2 Hrs.		Capped ? Yes		
Method										Pumping Method ?				
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?					
Surface									Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller										Lic #		Date Signed		
JP												08-15-2013		
Drill Rig Operator										Lic or Reg #		Date Signed		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Wastewater Sump		30
Building Overhang		10	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 09-09-2013

Updated On: 04-08-2020

Review Status: