

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VE512		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner CLASSIC CUSTOM HOMES						Phone # 8504450		1. Well Location				Fire # (if avail.)											
Mailing Address 800 S DIVISION ST STE A								Town of WINSOR															
City WAUNAKEE						State WI		Zip Code 53597															
County Dane		Co. Permit # 29634		Notification # 36929351		Completed 05-21-2010		Subdivision Name WINSOR GARDENS				Lot # 70											
								Block #															
Well Constructor (Business Name) HUEMANN T WELL & PUMP INC				Lic. # 6210		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code											
								°N °W															
Address 39608 60TH ST BURLINGTON WI 53105-7502				Well Plan Approval #		SW SE		Section 26		Township 9 N		Range 10 E											
Hicap Permanent Well #				Common Well #		Specific Capacity 10		2. Well Type New Well															
								of previous unique well #				constructed in											
								Reason for replaced or reconstructed well ?															
3. Well serves 1 # of				Hicap Well ? No																			
Private, potable				Hicap Property ? No																			
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		150		<u>Yes</u> Rotary - Mud Circulation				<u>No</u>		- - C -		CLAY		Surface		3					
6		150		175		<u>No</u> Rotary - Air				<u>Yes</u>		- - Y -		SAND & GRAVEL		3		65					
						Rotary - Air & Foam						- - N H		SANDSTONE & SHALE		65		168					
						Drill-Through Casing Hammer						- - N -		SANDSTONE		168		175					
						Reverse Rotary																	
						Cable-tool Bit ___ in. dia...																	
						Dual Rotary																	
						Temp. Outer Casing ___ in. dia																	
						Removed? ___ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		37 ft. below ground surface				12 in. above grade									
6		STEEL ASTM A53B NSF WC IPSCO PE				Surface		150		10. Pump Test				Developed ? Yes									
										Pumping level 40 ft. below surface				Disinfected ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 30 GP for 2 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method TREMIE PUMPED																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?													
PORTLAND CEMENT				Surface		150		30 S															
13. Constructor / Supervisory Driller														Lic #		Date Signed							
TH																05-25-2010							
Drill Rig Operator														Lic or Reg #		Date Signed							
BS																							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		38

Comment:

Created On: 06-21-2010

Updated On: 08-23-2010

Review Status: