Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VE512

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CLASSIC CUSTOM HOMES	Phone #: 8504450
Mailing Address: 800 S DIVISION ST STE A	
City: WAUNAKEE	State: WI — Zip Code: 53597
County: Dane	Co. Permit #: 29634 — Notification #: 36929351 — Completed: 05-21-2010
Well Constructor (Business Name): HUEMANN T WELL & PUMP INC	Lic #: 6210 — Facility ID # (Public Wells):
Address: 39608 60TH ST BURLINGTON WI 53105-7502	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 10

1. Well Location

Fire # (if avail.):

Town of WINSOR

Street Address or Road Name and Number: STEPPING STONE CIR

Subdivision Name: WINSOR GARDENS — Lot #: 70 — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW SE or Govt Lot #: — Section: 26 — Township: 9 N — Range: 10 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	150
6	150	175

Upper Enlarged Drillhole / Lower Open Bedrock

Yes / No — Rotary - Mud Circulation ..... — No

No / Yes — Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	3
-	-	Y	-	SAND & GRAVEL	3	65
-	-	N	H	SANDSTONE & SHALE	65	168
-	-	N	-	SANDSTONE	168	175

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL ASTM A53B NSF WC IPSCO PE	Surface	150
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

37 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 30 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	150	30 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TH		05-25-2010
Drill Rig Operator	Lic or Reg #	Date Signed
BS		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		38

Comment:

Created On: 06-21-2010 Updated On: 08-23-2010 Review Status: