

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VE793		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner CHRISTENSEN, PAUL						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address 641 E GRANT ST						Town of SHARON						3656											
City HASTINGS						State MI		Zip Code 49058				Street Address or Road Name and Number BENTLEY RD											
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #									
Portage				37860925		08-09-2010																	
Well Constructor (Business Name) JOHN D DILLENBURG				Lic. # 6331		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.64297 °N -89.4736 °W				Method Code GPS008									
Address DILLENBURG WELL DRLG SHAWANO WI 54166				Well Plan Approval #				SW SW		Section 18		Township 25 N		Range 9 E									
				Approval Date (mm-dd-yyyy)				or Govt Lot #															
Hicap Permanent Well #				Common Well #		Specific Capacity 1.2				2. Well Type New Well				of previous unique well #		constructed in							
Reason for replaced or reconstructed well ?																							
3. Well serves 1 # of				Hicap Well ? No				Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		85		Yes Rotary - Mud Circulation No								- - S -		SAND		Surface		7			
						Rotary - Air								- - S G		SAND & STONES		7		21			
						Rotary - Air & Foam								- - Y M		SILTY SAND, GRAVEL, STONES		21		71			
						Drill-Through Casing Hammer								- - Y M		SILTY SAND & GRAVEL		71		85			
						Reverse Rotary																	
						Cable-tool Bit ___ in. dia...																	
						Dual Rotary																	
						Temp. Outer Casing ___ in. dia																	
						Removed? ___ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		37 ft. below ground surface				22 in. above grade									
5		CRESTLINE PVC SDR17 ASTM D2241 SOLVENT WELD 20 SLOT				Surface		75		10. Pump Test				Developed ? Yes									
										Pumping level 58 ft. below surface				Disinfected ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 25 GP M for 2 Hrs.				Capped ? Yes									
5		PVC CONTINEOUS SLOT SCREEN				75		85		Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method TREMIE PIPE PUMPED																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No									
BENTONITE GROUT				Surface		65		S		NONE													
13. Constructor / Supervisory Driller								Lic #		Date Signed													
JD										08-30-2010													
Drill Rig Operator								Lic or Reg #		Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		118	Building Overhang		26
			Septic or Holding, or POWTS Tank		100

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	WCR Submit Time	08/31/2010	RECEIVED FAX OF WCR WITHIN REQUIRED 30 DAYS

Created On: 10-04-2010

Updated On: 05-07-2020

Review Status: