Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VE804

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MISHLER, CLIFF	Phone #
Mailing Address: N2253 BUTTERNUT RD	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #: — Notification #: 38584918 — Completed: 10-21-2010
Well Constructor (Business Name): JOHN D DILLENBURG	Lic. #: 6331 — Facility ID # (Public Wells):
Address: DILLENBURG WELL DRLG, SHAWANO WI 54166	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.4

1. Well Location

Town of DAYTON	Fire # (if avail.): N2259
Street Address or Road Name and Number: BUTTERNUT RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.3215 °N -89.18072 °W	Method Code: GPS008
NW SW or Govt Lot #:	Section: 4 — Township: 21 N — Range: 11 E

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	82

Upper Enlarged Drillhole: Yes
Lower Open Bedrock: No

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	16
-	-	Y	-	SAND & GRAVEL	16	51
-	N	S	-	FINE SAND	51	74
-	A	S	-	COARSE SAND	74	82

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	CRESTLINE PVC SDR 17 ASTM D2241 SOLVENT WELD	Surface	78
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS SCREEN 15 SLOT	78	82

7. Grout or Other Sealing Material

Method: TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GROUT	Surface	68	

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 30 GP for 2 Hrs.
Pumping Method ?

11. Well Is
21 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JD		11-08-2010
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		15	Building Overhang		12

Comment:

Created On: 01-11-2011 Updated On: 05-08-2020 Review Status: