

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VE804		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MISHLER, CLIFF						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N2253 BUTTERNUT RD						Town of DAYTON						N2259			
City WAUPACA						State WI		Zip Code 54981				Street Address or Road Name and Number BUTTERNUT RD			
County Waupaca		Co. Permit #		Notification # 38584918		Completed 10-21-2010		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) JOHN D DILLENBURG				Lic. # 6331		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3215 °N -89.18072 °W				Method Code GPS008	
Address DILLENBURG WELL DRLG SHAWANO WI 54166				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 4 21 N 11 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 1.4											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 8.75		From (ft.) Surface		To (ft.) 82		Upper Enlarged Drillhole <u>Yes</u> Rotary - Mud Circulation <u>No</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Lower Open Bedrock		8. Geology					
								Geology Codes - - S - SAND - - Y - SAND & GRAVEL - N S - FINE SAND - A S - COARSE SAND		Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) Surface 16 16 51 51 74 74 82					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is			
5		CRESTLINE PVC SDR 17 ASTM D2241 SOLVENT WELD				Surface		78		18 ft. below ground surface		21 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes			
6		JOHNSON SS SCREEN 15 SLOT				78		82		Pumping level 40 ft. below surface Pumping at 30 GP for 2 Hrs. Pumping Method ?					
7. Grout or Other Sealing Material															
Method TREMIE PIPE PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No NONE					
BENTONITE GROUT				Surface		68									
12. Notified Owner of need to fill & seal ?															
13. Constructor / Supervisory Driller JD Drill Rig Operator												Lic # Lic or Reg #		Date Signed 11-08-2010 Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		15	Building Overhang		12

Comment:

Created On: 01-11-2011

Updated On: 05-08-2020

Review Status: