Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VF185

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: AGRICAIR LLC, PERRIN, JIM	Phone #: (715)335-4470
Mailing Address: PO BOX 114	
City: BANCROFT	State: WI — Zip Code: 54921
County: Portage	Co. Permit #:
Notification #: 44911001	Completed: 07-11-2012
Well Constructor (Business Name): JOSEPH FARAGO	Lic. #: 284
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: FARAGO PLBG & TRENCHING INC PLAINFIELD WI 54966	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 4	

3. Well serves 1 # of BATHROOM
Non-community
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of PINE GROVE

Fire # (if avail.): 5485

Street Address or Road Name and Number: JESSIE JUDD RD

Subdivision Name	Lot #	Block #
CSM-9497		

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.32357 °N -89.51527 °W	GPS008

SW	SE	Section	Township	Range
or Govt Lot #		2	21 N	8 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NO WATER

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	26

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	36

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND ASTM A589 T&C .154 WALL WEIGHT-120	Surface	32
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	SS #12	32	36

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 12 ft. below surface
Pumping at 8 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JF		07-13-2012
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		53

Type	Qualifier	Distance
Building Overhang		3
Septic or Holding, or POWTS Tank		28

Comment:

Created On: 08-08-2012 Updated On: 05-07-2020 Review Status: