

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VH801		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ANIMAL TRACKS LLC, EICHMANN, K						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 3600 CO RD Q						Town of AMHERST													
City AMHERST JUNCTION						State WI		Zip Code 54407											
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #					
Portage				39073467		11-23-2010													
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code							
EDWARD J GRITZNER				273				44.48593 °N -89.31187 °W				GPS008							
Address ALPHA DRLG SERVICE INC AMHERST WI 54406-9161				Well Plan Approval #		SW NE Section Township Range													
				Approval Date (mm-dd-yyyy)		or Govt Lot #		8 23 N 10 E											
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well											
						3.3		of previous unique well #				constructed in							
3. Well serves 1 # of				Hicap Well ?		No		Reason for replaced or reconstructed well ?											
Private, potable				Hicap Property ?		No													
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type				Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		64						K - I -		BLACK DIRT		Surface		1			
						Rotary - Mud Circulation				T - C -		CLAY BROWN		1		3			
						Rotary - Air				- - S -		SAND		3		4			
						Rotary - Air & Foam				- - Y -		SAND GRAVEL		4		15			
						Drill-Through Casing Hammer				- - Y G		SAND GRAVEL COBBLES		15		21			
						Reverse Rotary				- - S -		SAND		21		64			
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				36 in. above grade					
6		6.625 X .280 PE WELDED A53 IPSCO				Surface		60		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 36 ft. below surface				Disinfected ? Yes					
5.5		SAINLESS S 8 SLOT				60		64		Pumping at 20 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method GRAVITY																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?									
BENSEAL (MOUNDED)				Surface						N/A									
13. Constructor / Supervisory Driller										Lic #		Date Signed							
Drill Rig Operator										Lic or Reg #		Date Signed							
EG												11-23-2010							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Building Overhang	>	20
			Septic or Holding, or POWTS Tank	>	80

Comment:

Created On: 01-11-2011

Updated On: 01-11-2011

Review Status: