Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VH805

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SWANLUND, TODD			Phone #
Mailing Address: 6314 PAYNES POINT RD			
City: NEENAH	State: WI	Zip Code: 54956	
County: Waupaca	Co. Permit #:	Notification #: 38705061	Completed: 11-08-2010

1. Well Location

Town of IOLA

Fire # (if avail.)

Street Address or Road Name and Number: 1905 E DOEDE

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
EDWARD J GRITZNER	273	

Latitude / Longitude in Decimal Degree (DD): 44.90197 °N -89.13382 °W

Method Code: GPS008

Address: ALPHA DRLG SERVICE INC
AMHERST WI 54406-9161

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

NW	SE	Section	Township	Range
or Govt Lot #		11	24 N	11 E

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NON COMPLY

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.8

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	53

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	-	I	-	BLACK DIRT	Surface	1
-	-	S	-	SAND	1	6
-	-	X	-	CLAY & SAND	6	10
-	-	S	-	SAND	10	49
-	N	S	-	SAND (MEDIUM)	49	53

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 X .280 PE A53 WELDED IPSCO	Surface	50
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.5	STAINLESS S 10 SLOT	50	53

9. Static Water Level

6 ft. below ground surface

10. Pump Test

Pumping level 17 ft. below surface

Pumping at 20 GP for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENSEAL (MOUNDED)	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EG		11-08-2010

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100

Type	Qualifier	Distance
Building Overhang		10
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-11-2011 Updated On: 01-11-2011 Review Status: