

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VH806		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SHULFER, EUGENE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 4005 SMOKEY RD						Town of STOCKTON													
City AMHERST						State WI		Zip Code 54406											
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #					
Portage				39112935		12-02-2010													
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code							
EDWARD J GRITZNER				273				44.4667 °N -89.37782 °W				GPS008							
Address ALPHA DRLG SERVICE INC AMHERST WI 54406-9161				Well Plan Approval #		NE SW		Section		Township		Range							
				Approval Date (mm-dd-yyyy)		or Govt Lot #		14		23 N		9 E							
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well											
						2		of previous unique well # constructed in											
3. Well serves 1 # of				Hicap Well ?		No		Reason for replaced or reconstructed well ?											
Private, potable				Hicap Property ?		No													
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		144								- - I M		SILTY LOAM		Surface		0.5	
Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						- - S U				DIRTY SSAND		0.5		6					
						- - X -				SAND & CLAY		6		19					
						- - S G				SAND & TRACE GRAVEL		19		65					
						- - C -				CLAY		65		74					
						- - S U				MUDDY, SAND		74		138					
						- - Y -				SAND & GRAVEL		138		144					
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		57 ft. below ground surface				36 in. above grade					
6		6.625 X .280 P.E. WELDED A-53 IPSCO				Surface		140		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 67 ft. below surface				Disinfected ? Yes					
5.5		STAINLESS TELE 8 SLOT				140		144		Pumping at 20 GP M for 3 Hrs.				Capped ? Yes					
						Pumping Method ?													
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?													
Method GRAVITY																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?											
BENSEAL (MOUNDED)		Surface						N/A											
						13. Constructor / Supervisory Driller				Lic #		Date Signed							
						Drill Rig Operator				Lic or Reg #		Date Signed							
						EG						12-02-2010							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NONE AT DRILLING

Created On: 02-03-2011

Updated On: 02-22-2011

Review Status: