Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VH806

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SHULFER, EUGENE			Phone #
Mailing Address: 4005 SMOKEY RD			
City: AMHERST	State: WI	Zip Code: 54406	
County: Portage	Co. Permit #:	Notification #: 39112935	Completed: 12-02-2010

Well Constructor (Business Name): EDWARD J GRITZNER	Lic. #: 273	Facility ID # (Public Wells):	
Address: ALPHA DRLG SERVICE INC AMHERST WI 54406-9161		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2	

1. Well Location

Town of STOCKTON

Fire # (if avail.)

Street Address or Road Name and Number: CO RD K

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.4667 °N -89.37782 °W

Method Code: GPS008

NE	SW	Section	Township	Range
or Govt Lot #		14	23 N	9 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	144

Upper Enlarged Drillhole

Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	M	SILTY LOAM	Surface	0.5
-	-	S	U	DIRTY SSAND	0.5	6
-	-	X	-	SAND & CLAY	6	19
-	-	S	G	SAND & TRACE GRAVEL	19	65
-	-	C	-	CLAY	65	74
-	-	S	U	MUDDY, SAND	74	138
-	-	Y	-	SAND & GRAVEL	138	144

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 X .280 P.E. WELDED A-53 IPSCO	Surface	140
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.5	STAINLESS TELE 8 SLOT	140	144

9. Static Water Level

57 ft. below ground surface

10. Pump Test

Pumping level 67 ft. below surface

Pumping at 20 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

36 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENSEAL (MOUNDED)	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed
EG		12-02-2010

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NONE AT DRILLING

Created On: 02-03-2011 Updated On: 02-22-2011 Review Status: