Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VH807

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DIVER, CHARLES			Phone #
Mailing Address: 8960 CO RD B			
City: AMHERST	State: WI	Zip Code: 54406	
County: Portage	Co. Permit #:	Notification #: 40291552	Completed: 05-12-2011

Well Constructor (Business Name): EDWARD J GRITZNER	Lic. #: 273	Facility ID # (Public Wells):	
Address: ALPHA DRLG SERVICE INC AMHERST WI 54406-9161		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.5	

1. Well Location

Village of NELSONVILLE

Fire # (if avail.)

Street Address or Road Name and Number: 3030 HIGH ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.49642 °N -89.3119 °W

Method Code: GPS008

NW SE or Govt Lot #	Section	Township	Range
	5	23 N	10 E

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NO WATER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	61.5

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	-	I	-	BLACK DIRT	Surface	1
T	-	C	-	CLAY (BROWN)	1	4
-	-	S	-	SAND	4	22
-	-	X	-	SAND & CLAY	22	55
-	-	S	G	SAND & TRACE GRAVEL	55	61.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625 X .280 PE WELDED A53 IPSCO	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.5	SS ALLOY MACH 8 SLOT	58	61.5

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 19 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MOUNDED	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EG		05-12-2011

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105	Building Overhang		34
			Septic or Holding, or POWTS Tank		38

Comment:

Created On: 06-20-2011 Updated On: 06-20-2011 Review Status: