# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* VJ568

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | | | |
|---|---|---|---|
| Property Owner: KOCH, GREG | | | Phone #: (715)424-1042 |
| Mailing Address: 6520 S PARK DR | | | |
| City: WISCONSIN RAPIDS | State: WI | Zip Code: 54494 | |
| County: Wood | Co. Permit #: | Notification #: 7073779301 | Completed: 01-10-2018 |

| | | | |
|---|---|---|---|
| Well Constructor (Business Name): KEVIN J POWELL | Lic. #: 4272 | Facility ID # (Public Wells): | |
| Address: POWELL PLUMBING & PUMPS INC<br>WISCONSIN RAPIDS WI 54494 | | Well Plan Approval #: | |
| | | Approval Date (mm-dd-yyyy): | |
| Hicap Permanent Well #: | Common Well #: | Specific Capacity: | |

**3. Well serves** 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

**1. Well Location**
Town of GRAND RAPIDS

Fire # (if avail.):

Street Address or Road Name and Number: 6520 S PARK DR

| | | |
|---|---|---|
| Subdivision Name: | Lot #: | Block #: |

| | | | |
|---|---|---|---|
| Latitude / Longitude in Decimal Degree (DD): 44.36086 °N -89.74322 °W | | | Method Code: GPS008 |
| SW NW or Govt Lot # | Section: 25 | Township: 22 N | Range: 6 E |

**2. Well Type** Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
BASEMENT WELL

Construction Type: Driven Point

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 2 | Surface | 31 |

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

**8. Geology**

| Geology Codes | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|
| - - S - | SAND | Surface | 31 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 2 | WHEATLAND T&C 0.154 WALL 3.68/LBS/FT | Surface | 27 |
| **Dia. (in.)** | **Screen type, material & slot size** | **From (ft.)** | **To (ft.)** |
| 2 | JOHNSOBN SS 10 SLOT | 27 | 31 |

**7. Grout or Other Sealing Material**
Method

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| | Surface | | |

**9. Static Water Level**
17 ft. below ground surface

**10. Pump Test**
Pumping level _____ ft. below surface
Pumping at _____ GP for _____ Hrs.
Pumping Method ?

**11. Well Is**
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**12.** Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| KP | | 01-17-2018 |
| **Drill Rig Operator** | **Lic or Reg #** | **Date Signed** |
| | | |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS dispersal component (soil absorption unit or mound) | > | 50 | Septic or Holding, or POWTS Tank | | 25 |

Comment:

Created On: 02-06-2018 Updated On: 05-05-2020 Review Status: