Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VJ569

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KNOBECK, LON			Phone #: (715)213-8373
Mailing Address: 5710 32ND ST S			
City: WISCONSIN RAPIDS	State: WI	Zip Code: 54494	
County: Wood	Co. Permit #:	Notification #: 7089008301	Completed: 02-27-2018

1. Well Location

Town of GRAND RAPIDS

Fire # (if avail.)

Street Address or Road Name and Number: 3720 PLOVER RD

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
KEVIN J POWELL	4272	

Latitude / Longitude in Decimal Degree (DD): 44.40939 °N -89.77986 °W

Method Code: GPS008

Well Plan Approval #:

NE	NW	Section	Township	Range
or Govt Lot #		10	22 N	6 E

Address: POWELL PLUMBING & PUMPS INC
WISCONSIN RAPIDS WI 54494

Approval Date (mm-dd-yyyy):

2. Well Type Replacement

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity

Reason for replaced or reconstructed well ?

WELL IN CRAWL SPACE

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	28

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - S -	SAND	Surface	28

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND 0.154 WALL 3.68/LBS/FT T&C	Surface	25
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	#10 SS ALLOY	25	28

9. Static Water Level

9 ft. below ground surface

10. Pump Test

Pumping level _____ ft. below surface

Pumping at _____ GP for _____ Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KP		02-28-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50

Type	Qualifier	Distance
Sewer - Building Sanitary		8
Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 03-27-2018 Updated On: 05-05-2020 Review Status: