Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VJ583

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SMITH, JEFF			Phone #: (320)839-1244
Mailing Address: 6711 LENOX AVE			
City: WISCONSIN RAPIDS	State: WI	Zip Code: 54494	
County: Wood	Co. Permit #:	Notification #: 6922972601	Completed: 08-22-2017

Well Constructor (Business Name): KEVIN J POWELL	Lic. #: 4272	Facility ID # (Public Wells):
Address: POWELL PLUMBING & PUMPS INC WISCONSIN RAPIDS WI 54494		Well Plan Approval #: Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity:

1. Well Location

Town of GRAND RAPIDS

Fire # (if avail.):

Street Address or Road Name and Number: 6711 LENOX AVE

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.37491 °N -89.74098 °W

Method Code: GPS008

SW NE or Govt Lot #:	Section: 24	Township: 22 N	Range: 6 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: PLUGGED POINT

Construction Type: Driven Point

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	28

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - S -	SAND	Surface	28

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND A-53-T&C 0.154-WALL 3.68LBS/FT	Surface	25
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	SS ALLOY MACHINE #10	25	28

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

9 ft. below ground surface

10. Pump Test

Pumping level _____ ft. below surface

Pumping at _____ GP for _____ Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
		08-22-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Wastewater Sump	>	8
			Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 01-22-2018 Updated On: 01-22-2018 Review Status: