

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VJ836		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JOHNSON, MIKE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 4560 ELMWOOD RD						Town of WARREN						4735							
City HUBERTUS						State WI		Zip Code 53033				Street Address or Road Name and Number							
4735 W CHICAGO DR						Subdivision Name				Lot #		Block #							
County Waushara		Co. Permit #		Notification # 52309458		Completed 08-08-2014		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Well Constructor (Business Name) WAYNE W SALEFSKY				Lic. # 567		Facility ID # (Public Wells)				44.0621 °N -89.1189 °W		GCD013							
Address TOWN & COUNTRY WELL DRILLING BERLIN WI 54923-0123				Well Plan Approval #		NE SW		Section 6		Township 18 N		Range 12 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #		6		18 N		12 E							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5		2. Well Type New Well				of previous unique well # constructed in									
3. Well serves 1 # of Private, potable						Hicap Well ? No		Reason for replaced or reconstructed well ?											
Heat Exchange ___ # of drillholes						Hicap Property ? No		Construction Type Drilled											
Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock									
6		Surface		128		Rotary - Mud Circulation													
6		128		140		Rotary - Air													
Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Yes				Yes									
8. Geology																			
Dia. (in.)				Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		T&C ASTM A53B NEW BLACK STEEL 19.45 LB PER FT VSP CO HYDRO TESTED 1780 PSI		Surface		128		- - S -		SAND		Surface		80					
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)		- - C -		CLAY		80		128					
								- N - -		SAND STONE		128		140					
6. Casing, Liner, Screen																			
Dia. (in.)				Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level							
6				T&C ASTM A53B NEW BLACK STEEL 19.45 LB PER FT VSP CO HYDRO TESTED 1780 PSI				Surface		128		40 ft. below ground surface							
Dia. (in.)				Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test							
												Pumping level 60 ft. below surface							
												Pumping at 30 GP M for 3 Hrs.							
												Pumping Method ?							
7. Grout or Other Sealing Material																			
Method																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		11. Well Is									
#8 BENTONITE				Surface						14 in. above grade									
										Developed ? Yes									
										Disinfected ? Yes									
										Capped ? Yes									
12. Notified Owner of need to fill & seal ?																			
Filled & Sealed Well(s) as needed?																			
NONE																			
13. Constructor / Supervisory Driller				Lic #		Date Signed													
WS						09-09-2014													
Drill Rig Operator				Lic or Reg #		Date Signed													
SS						09-09-2014													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 10-01-2014

Updated On: 05-05-2020

Review Status: