

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VK637		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner CONNEL, TERRY						Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address 22702 SELVIG RD						Town of SIREN						22702		
City SIREN						State WI		Zip Code 54872				Street Address or Road Name and Number SELVIG RD		
County Burnett		Co. Permit #		Notification # 20954287		Completed 10-03-2005		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) THOMAS G BUTTERFIELD				Lic. # 555		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.7381 °N -92.3596 °W			Method Code GCD013	
Address 6380 N COUNTY RD E STONE LAKE WI 54876				Well Plan Approval #		NE NW		Section 33		Township 38 N		Range 16 W		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 3		2. Well Type New Well								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
						Hicap Property ? No								
						Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) 8.75		From (ft.) Surface		To (ft.) 37		Upper Enlarged Drillhole				Lower Open Bedrock				
						Yes Rotary - Mud Circulation No								
						Rotary - Air								
						Rotary - Air & Foam								
						Drill-Through Casing Hammer								
						Reverse Rotary								
						Cable-tool Bit ___ in. dia...								
						Dual Rotary								
						Temp. Outer Casing ___ in. dia								
						Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)				
- - F -		FILL						Surface		2				
T A S -		TAN/BROWN, COARSE, SAND						2		8				
T A Z M		TAN/BROWN, COARSE, CLAY & GRAVEL, SILTY						8		28				
T M S -		TAN/BROWN, MEDIUM, SAND						28		37				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				
5		EAGLE PVC 1120 SDR 21 200 PSI ASTM F-480				Surface		32		25 ft. below ground surface				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				
5		30 CONTINUOUS S SLOT JOHNSON PVC				32		37		Pumping level 27 ft. below surface				
										Pumping at 6 GP M for 1 Hrs.				
										Pumping Method ?				
7. Grout or Other Sealing Material														
Method TREMIE PIPE - PUMPED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		11. Well Is				
HIGH SOLID BENTONITE GROUT				Surface		32				14 in. above grade				
										Developed ? Yes				
										Disinfected ? Yes				
										Capped ? Yes				
12. Notified Owner of need to fill & seal ?														
										Filled & Sealed Well(s) as needed? No				
										N/A				
13. Constructor / Supervisory Driller								Lic #		Date Signed				
										10-04-2005				
Drill Rig Operator								Lic or Reg #		Date Signed				
										10-04-2005				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Building Overhang		25
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 08-24-2009

Updated On: 06-30-2020

Review Status: