

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VK640		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SCHULTZ, GUS						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 12711 N BIRCH POINT RD						Town of SPIDER LAKE						12711									
City HAYWARD						State WI		Zip Code 54843				Street Address or Road Name and Number BIRCH POINT LN									
County Sawyer		Co. Permit #		Notification # 20863706		Completed 10-10-2005		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) THOMAS G BUTTERFIELD				Lic. # 555		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.0903 °N -91.108 °W				Method Code GCD013							
Address 6380 N COUNTY RD E STONE LAKE WI 54876				Well Plan Approval #		SE NW		Section 27		Township 42 N		Range 6 W									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled															
3. Well serves 1 # of Private, potable				Hicap Well ? No																	
Heat Exchange ___ # of drillholes				Hicap Property ? No																	
				Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		147		Yes Rotary - Mud Circulation No								- - F - FILL		Surface		2			
						Rotary - Air				T - X - TAN/BROWN, SAND & CLAY				2		25					
						Rotary - Air & Foam				T A S - TAN/BROWN, COARSE, SAND				25		115					
						Drill-Through Casing Hammer				T A G - TAN/BROWN, COARSE, GRAVEL/COBBLES/BOULDER				115		147					
						Reverse Rotary															
						Cable-tool Bit ___ in. dia...															
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11 ft. below ground surface				14 in. above grade							
5		EAGLE PVC 1120 SDR 21 200 PSI ASTM F-480				Surface		142		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 100 ft. below surface				Disinfected ? Yes							
5		30 CONTINUOUS SLOT JOHNSON PVC				142		147		Pumping at 6 GP M for 1 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED						Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No N/A											
						Kind of Sealing Material								From (ft.)		To (ft.)		# Sacks Cement			
HIGH SOLID BENTONITE GROUT						Surface		142													
13. Constructor / Supervisory Driller														Lic #		Date Signed					
																10-11-2005					
Drill Rig Operator														Lic or Reg #		Date Signed					
																10-11-2005					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Shoreline/Pool		150
Building Overhang		25	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 08-24-2009

Updated On: 06-24-2020

Review Status: