

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				VL141		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner AL & SUSAN BUTTERFIELD						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address PO BOX 1165						Town of BARKSDALE						73815									
City BAYFIELD						State WI		Zip Code 54814				Street Address or Road Name and Number ONDOSSAGON ROAD									
County Bayfield		Co. Permit #		Notification # 21862350		Completed 01-27-2006		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) TRAVIS A BUTTERFIELD				Lic. # 6349		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.6423 °N -90.9693 °W				Method Code GCD013							
Address 14346 W STATE RD 77 HAYWARD WI 54843-4085				Well Plan Approval #				SE NE		Section 15		Township 48 N		Range 5 W							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				2. Well Type New Well											
3. Well serves 1 # of				Hicap Well ? No				of previous unique well #				constructed in									
Private, potable				Hicap Property ? No				Reason for replaced or reconstructed well ?													
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		243		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>Yes</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> Dual Rotary <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						R - C - Red, Clay T - Y M Tan/Brown, Sand & Gravel, Silty T - G C Tan/Brown, Gravel/Cobbles/Boulders/Stones, Clayey G - Y C Gray, Sand & Gravel, Clayey G H Z - Gray, Hard/Firm, Clay & Gravel T B N - Tan/Brown, Broken, Sandstone T - N - Tan/Brown, Sandstone		Surface 12 35 140 140 155 190 190 194 243							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		103 ft. below ground surface				14 in. above grade							
6		NEW P&E BLACK-WELDED 18.97LB/FT ASTM A53B SAWHILL				Surface		194		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 140 ft. below surface Pumping at 10 GP M for 2 Hrs. Pumping Method ?											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?									
Method MOUNDED																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No							
BENTONITE				Surface		20		2		N/A											
												13. Constructor / Supervisory Driller				Lic #		Date Signed			
												TAB								01-30-2006	
												Drill Rig Operator				Lic or Reg #		Date Signed			
												DLB								01-30-2006	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 02-03-2006

Updated On: 06-25-2020

Review Status: APPROVED