Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VL144

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GERBER, AL			Phone #
Mailing Address: PO BOX 36			
City: RADISSON	State: WI	Zip Code: 54867	
County: Sawyer	Co. Permit #:	Notification #: 22071716	Completed: 02-02-2006

1. Well Location

Town of WEIRGOR

Fire # (if avail.): 1932N

Street Address or Road Name and Number: HWY 40

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): TRAVIS A BUTTERFIELD	Lic. #: 6349	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 45.7085 °N -91.2242 °W
			Method Code: GCD013
		Well Plan Approval #	SW NE or Govt Lot #:	Section: 10	Township: 37 N	Range: 7 W
Address: 14346 W STATE RD 77 HAYWARD WI 54843-4085		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.5	

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	99

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	X	G	Tan/Brown, Sand & Clay, w/Gravel/Cobbles/Boulders/Stones	Surface	15
T	-	Y	-	Tan/Brown, Sand & Gravel	15	40
T	-	C	G	Tan/Brown, Clay, w/Gravel/Cobbles/Boulders/Stones	40	75
T	A	G	C	Tan/Brown, Coarse, Gravel/Cobbles/Boulders/Stones, Clayey	75	87
T	-	Y	M	Tan/Brown, Sand & Gravel, Silty	87	99

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P&E BLACK WELDED 18.97LB/FT ASTM A53B SAWHILL	Surface	96
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	25 CONTINUOUS SLOT STAINLESS STEEL	96	99

9. Static Water Level

58 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	20	2

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAB		02-03-2006
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DLB		02-03-2006

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		58	Shoreline/Pool		100
Building Overhang		31	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 03-03-2006 Updated On: 06-24-2020 Review Status: APPROVED