Well Construction Report
WISCONSIN UNIQUE WELL NUMBER VL158

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KONIECZNY, PAUL & TRACI	Phone #: (262)968-4488
Mailing Address: S23 W33547 MORRIS RD	
City: OCONOMOWOC	State: WI Zip Code: 53066

County	Co. Permit #	Notification #	Completed
Dane	25644	21848969	12-29-2005

Well Constructor (Business Name): AQUA WELL & PUMP SYSTEMS INC	Lic. #: 427	Facility ID # (Public Wells):
Address: 124 N OAKRIDGE DR NORTH PRAIRIE WI 53153-9792		Well Plan Approval #: Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of CHRISTIANA

Fire # (if avail.):

Street Address or Road Name and Number: 372 CTY RD A

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
42.9359 °N -89.0405 °W	GCD013

SW SE or Govt Lot #	Section	Township	Range
	35	6 N	12 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NON-COMPLYING

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	X	-	Sand & Clay	Surface	3
-	-	Y	-	Sand & Gravel	3	16
-	-	X	-	Sand & Clay	16	34
-	-	C	-	Clay	34	88
R	-	L	-	Red, Limestone/Dolomite	88	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 LB PF .280 ASTM A53 IPSCO WELDED	Surface	88
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MESH GRANULAR BENTONITE	Surface		

9. Static Water Level
31 ft. below ground surface

10. Pump Test
Pumping level 66 ft. below surface
Pumping at 20 GP M for 1.5 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TC		01-12-2006
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		15
			Septic or Holding, or POWTS Tank		35

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	10/24/2006	WILL SAMPLE SOON. RENOVATING HOME

Created On: 01-24-2006 Updated On: 12-11-2019 Review Status: APPROVED