

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WH623		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ANDERSON, KATIE						Phone # 715		1. Well Location				Fire # (if avail.)	
Mailing Address 37055 HWY 169						Town of MORSE							
City MELLON						State WI		Zip Code 54546					
County Ashland		Co. Permit #		Notification # 29269099		Completed 05-01-2008		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) PEPPER R CRAFT				Lic. # 6808		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address PO BOX 145 LAKE NEBAGAMON WI 54849				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 29 45 N 2 W		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Property ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology				
9 Surface 40			<u>Yes</u> Rotary - Mud Circulation			<u>No</u>			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		
6 40 436			<u>No</u> Rotary - Air			<u>Yes</u>			- - C -		Clay		
			<u>No</u> Rotary - Air & Foam			<u>No</u>			B - Q -		Black, Granite		
			<u>No</u> Drill-Through Casing Hammer										
			<u>No</u> Reverse Rotary										
			<u>No</u> Cable-tool Bit ___ in. dia...			<u>No</u>							
			<u>No</u> Dual Rotary										
			<u>No</u> Temp. Outer Casing ___ in. dia										
			<u>No</u> Removed? ___ depth ft. (If NO explain on back side)										
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 16 in. above grade			
6		Plainend IPSCO A 53 B				Surface		40					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes			
										Disinfected ? Yes			
										Capped ? Yes			
7. Grout or Other Sealing Material													
Method Bradenhead													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?			
Neat cement grout				Surface		40		8 S					
13. Constructor / Supervisory Driller													
PC				Lic #		Date Signed		03-04-2009					
Drill Rig Operator				Lic or Reg #		Date Signed		03-04-2009					
PC													

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-14-2009

Updated On: 04-16-2009

Review Status: APPROVED