Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WH624

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HAVERY, DON JR	Phone #: (715)374-2551
Mailing Address: 6661 S WASGREN RD	
City: LAKE NEBAGAMON	State: WI — Zip Code: 54849
County: Douglas	Co. Permit #:
Notification #: 31133933	Completed: 09-01-2008
Well Constructor (Business Name): PEPPER R CRAFT	Lic. #: 6808
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: PO BOX 145 LAKE NEBAGAMON WI 54849	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.1	

1. Well Location

Village of LAKE NEBAGAMON	Fire # (if avail.): 6661
Street Address or Road Name and Number: WASGREN	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.5234 °N -91.7146 °W	Method Code: GCD013
NE SW or Govt Lot #:	Section: 26 — Township: 47 N — Range: 11 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	173
6	173	294

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	Y	-	Tan/Brown, Soft/Loose, Sand & Gravel	Surface	26
T	H	P	G	Tan/Brown, Hard/Firm, Hardpan, w/Gravel/Cobbles/Boulders/Stones	26	111
O	S	P	-	Orange, Soft/Loose, Hardpan	111	148
R	H	P	G	Red, Hard/Firm, Hardpan, w/Gravel/Cobbles/Boulders/Stones	148	173
R	-	B	-	Red, Basalt or Trap Rock	173	294

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Plainend IPSCO A 53 B	Surface	173
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

38 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 8 GP M for 10 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Drill mud and cuttings	Surface	173	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
PC		03-04-2009
Drill Rig Operator	Lic or Reg #	Date Signed
PC		03-04-2009

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		50	Septic or Holding, or POWTS Tank		200

Comment:

Created On: 03-06-2009 Updated On: 06-25-2020 Review Status: APPROVED