Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WH625

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: GOTTLIEB, RITA	Phone #: (715)374-2551
Mailing Address: PO BOX 145	
City: LAKE NEBAGAMON	State: WI — Zip Code: 54849
County: Douglas	Co. Permit #:
Notification #: 31148007	Completed: 11-10-2008
Well Constructor (Business Name): PEPPER R CRAFT	Lic. #: 6808
Facility ID # (Public Wells):	
Address: PO BOX 145 LAKE NEBAGAMON WI 54849	Well Plan Approval #:
	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location
Town of PARKLAND

Fire # (if avail.):

Street Address or Road Name and Number: RIVORD RD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NE NW or Govt Lot #: | Section: 31 | Township: 48 N | Range: 13 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	173
6	173	231

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	C	-	Red, Clay	Surface	117
R	-	P	-	Red, Hardpan	117	160
I	S	P	G	White, Soft/Loose, Hardpan, w/Gravel/Cobbles/Boulders/Stones	160	173
R	-	N	-	Red, Sandstone	173	231

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Plainend IPSCO A 53 B	Surface	173
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
66 ft. above ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 10 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
22 in. below grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Drill mud and cuttings	Surface	173	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
pc		03-04-2009
Drill Rig Operator	Lic or Reg #	Date Signed
PC		03-04-2009

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		65

Comment:

Created On: 03-06-2009 Updated On: 10-15-2026 Review Status: APPROVED