Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WH626

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: JACOBSON, JODY	Phone #: (715)374-2588
Mailing Address: 6757 S CARLSON RD	
City: LAKE NEBAGAMON	State: WI — Zip Code: 54849
County: Douglas	Co. Permit #:
Notification #: 32107416	Completed: 08-30-2008
Well Constructor (Business Name): PEPPER R CRAFT	Lic. #: 6808
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: PO BOX 145 LAKE NEBAGAMON WI 54849	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.1	

1. Well Location

Town of LAKE NEBAGAMON	Fire # (if avail.): 6757
Street Address or Road Name and Number: CARLSON RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.5188 °N -91.7563 °W	Method Code: GCD013
SE SW or Govt Lot #:	Section: 28 — Township: 47 N — Range: 11 W

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	58
6	58	310

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Plainend IPSCO A 53 B	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Drill mud and cuttings	Surface	58	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	M	Y	-	Tan/Brown, Medium, Sand & Gravel	Surface	26
R	H	P	-	Red, Hard/Firm, Hardpan	26	40
T	H	Y	P	Tan/Brown, Hard/Firm, Sand & Gravel, w/Hardpan	40	58
R	H	B	-	Red, Hard/Firm, Basalt or Trap Rock	58	310

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 12 GP M for 60 Hrs.
Pumping Method ?

11. Well Is
28 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
PC		03-06-2009
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
P_C		03-06-2009

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-06-2009 Updated On: 06-25-2020 Review Status: APPROVED