

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WN634		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner LIMBERG, BRIAN						Phone # (920)377-1992		1. Well Location				Fire # (if avail.)							
Mailing Address N6260 RIVER HEIGHTS						Town of PLYMOUTH						N6260							
City PLYMOUTH						State WI		Zip Code 53073				Street Address or Road Name and Number N6260 RIVER HEIGHTS DRIVE							
County Sheboygan		Co. Permit #		Notification # 34948903		Completed 11-16-2009		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) WAGNER BROTHERS WELL DRILLING INC				Lic. # 654		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.7648 °N -87.98 °W				Method Code GCD013					
Address W2282 COUNTY HWY WH MT CALVARY WI 53057-9720				Well Plan Approval #				SW SW		Section 15		Township 15 N		Range 21 E					
				Approval Date (mm-dd-yyyy)				or Govt Lot #											
Hicap Permanent Well #				Common Well #		Specific Capacity 4				2. Well Type New Well									
Hicap Property ? No				Hicap Potable ?				Reason for replaced or reconstructed well ?											
Heat Exchange ___ # of drillholes				Hicap Well ? No				Construction Type Drilled											
3. Well serves 1 # of HOUSE																			
Private, potable																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		122		No Rotary - Mud Circulation				No		T - P -		Tan/Brown, Hardpan		Surface		20	
						Yes Rotary - Air				Yes		T - X -		Tan/Brown, Sand & Clay		20		60	
						No Rotary - Air & Foam				No		T - G -		Tan/Brown, Gravel/Cobbles/Boulders/Stones		60		66	
						No Drill-Through Casing Hammer						- - L -		Limestone/Dolomite		66		122	
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...				No									
						Dual Rotary													
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		25 ft. below ground surface				18 in. above grade					
6		NEW PE 18.97 STEEL ASTM A53 .280 WALL IPSCO				Surface		66		10. Pump Test				Developed ? Yes					
										Pumping level 30 ft. below surface				Disinfected ? Yes					
										Pumping at 20 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
Granular bentonite				Surface		66		18		JW						11-17-2009			
										Drill Rig Operator				Lic or Reg #		Date Signed			
										MF						11-17-2009			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		60
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 11-17-2009

Updated On: 10-09-2019

Review Status: APPROVED