Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WN636

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GEISTARDHT, DAN	Phone #: (608)365-2170
Mailing Address: N6829 IRENE DRIVE	
City: FOND DU LAC	State: WI — Zip Code: 54935
County: Fond du Lac	Co. Permit #:
Notification #: 34834894	Completed: 12-08-2009
Well Constructor (Business Name): WAGNER BROTHERS WELL DRILLING INC	Lic. #: 654
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: W2282 COUNTY HWY WH MT CALVARY WI 53057-9720	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 7.5	

1. Well Location

Town of EMPIRE				Fire # (if avail.): N6829
Street Address or Road Name and Number: N6829 IRENE DRIVE				
Subdivision Name:			Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 43.7877 °N -88.3697 °W				Method Code: GCD013
NW NE or Govt Lot #:	Section: 8	Township: 15 N	Range: 18 E	

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	42
6	42	122

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - P -	Tan/Brown, Hardpan	Surface	26
T - L -	Tan/Brown, Limestone/Dolomite	26	100
U - H -	Blue, Shale	100	122

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PE 18.97 STEEL .280 WALL ASTM A53 IPSCO	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 62 ft. below surface

Pumping at 15 GP M for 0.5 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method Tremie Pipe - Pumped

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat cement grout	Surface	42	12 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		12-17-2009
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MF		12-17-2009

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100

Type	Qualifier	Distance
Building Overhang		20
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 01-05-2010 Updated On: 10-08-2019 Review Status: APPROVED