

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WN636		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner GEISTARDHT, DAN						Phone # (608)365-2170		1. Well Location				Fire # (if avail.)			
Mailing Address N6829 IRENE DRIVE						Town of EMPIRE						N6829			
City FOND DU LAC						State WI		Zip Code 54935				Street Address or Road Name and Number N6829 IRENE DRIVE			
County Fond du Lac		Co. Permit #		Notification # 34834894		Completed 12-08-2009		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) WAGNER BROTHERS WELL DRILLING INC				Lic. # 654		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.7877 °N -88.3697 °W				Method Code GCD013	
Address W2282 COUNTY HWY WH MT CALVARY WI 53057-9720				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 8 15 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 7.5											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology						
8 Surface 42			No Rotary - Mud Circulation No			T - P - Tan/Brown, Hardpan Surface 26			Type, Caving/Noncaving, Color, Hardness, etc...						
6 42 122			Yes Rotary - Air Yes			T - L - Tan/Brown, Limestone/Dolomite 26 100									
			No Rotary - Air & Foam No			U - H - Blue, Shale 100 122									
			No Drill-Through Casing Hammer												
			No Reverse Rotary												
			No Cable-tool Bit ___ in. dia... No												
			Dual Rotary												
			No Temp. Outer Casing ___ in. dia												
			No Removed? ___ depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		9. Static Water Level				11. Well Is			
6		NEW PE 18.97 STEEL .280 WALL ASTM A53 IPSCO				Surface 42		60 ft. below ground surface				24 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes			
								Pumping level 62 ft. below surface Pumping at 15 GP M for 0.5 Hrs. Pumping Method ?							
7. Grout or Other Sealing Material															
Method Tremie Pipe - Pumped															
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?									
Neat cement grout		Surface 42		12 S		Filled & Sealed Well(s) as needed?									
13. Constructor / Supervisory Driller															
JW				Lic #		Date Signed 12-17-2009									
Drill Rig Operator				Lic or Reg #		Date Signed									
MF						12-17-2009									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		20
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 01-05-2010

Updated On: 10-08-2019

Review Status: APPROVED