

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WN637		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ROBERTS, JIM						Phone # (608)365-2170		1. Well Location				Fire # (if avail.)							
Mailing Address N6091 WESTVIEW COURT						Town of FOND DU LAC						N6091							
City FOND DU LAC						State WI		Zip Code 54935				Street Address or Road Name and Number N6091 WESTVIEW COURT							
County Fond du Lac		Co. Permit #		Notification # 35361126		Completed 12-22-2009		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) WAGNER BROTHERS WELL DRILLING INC				Lic. # 654		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.7622 °N -88.5033 °W				Method Code GCD013					
Address W2282 COUNTY HWY WH MT CALVARY WI 53057-9720				Well Plan Approval #		NE NE		Section 19		Township 15 N		Range 17 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 10		2. Well Type New Well						of previous unique well # constructed in							
3. Well serves 2 # of Homes Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ?						Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		122		<u>No</u> Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... Dual Rotary <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				R - C - G - Z - G - L -		Red, Clay Gray, Clay & Gravel Gray, Limestone/Dolomite		Surface 40 82 122					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		47 ft. below ground surface				12 in. above grade					
6		NEW P.E. 18.97 STEEL ASTM A53 .280 WALL IPSCO				Surface		83		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 49 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement Granular bentonite Surface 5												Filled & Sealed Well(s) as needed?							
13. Constructor / Supervisory Driller								Lic #		Date Signed									
JW										12-28-2009									
Drill Rig Operator								Lic or Reg #		Date Signed									
MF										12-28-2009									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		30	Collector Sewer - San or Storm		50
			Sewer - Building Sanitary		60

Comment:

Created On: 01-05-2010

Updated On: 10-08-2019

Review Status: APPROVED