Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WN637

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROBERTS, JIM	Phone #: (608)365-2170
Mailing Address: N6091 WESTVIEW COURT	
City: FOND DU LAC	State: WI — Zip Code: 54935
County: Fond du Lac	Co. Permit #:
Notification #: 35361126	Completed: 12-22-2009
Well Constructor (Business Name): WAGNER BROTHERS WELL DRILLING INC	Lic. #: 654
Facility ID # (Public Wells):	
Address: W2282 COUNTY HWY WH MT CALVARY WI 53057-9720	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 10	

1. Well Location

Town of FOND DU LAC				Fire # (if avail.): N6091
Street Address or Road Name and Number: N6091 WESTVIEW COURT				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 43.7622 °N -88.5033 °W				Method Code: GCD013
NE	NE	Section: 19	Township: 15 N	Range: 17 E
or Govt Lot #				

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 2 # of Homes

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	122

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	C	-	Red, Clay	Surface	40
G	-	Z	-	Gray, Clay & Gravel	40	82
G	-	L	-	Gray, Limestone/Dolomite	82	122

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P.E. 18.97 STEEL ASTM A53 .280 WALL IPSCO	Surface	83
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

47 ft. below ground surface

10. Pump Test

Pumping level 49 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Granular bentonite	Surface		5

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		12-28-2009
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MF		12-28-2009

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		30	Collector Sewer - San or Storm		50
			Sewer - Building Sanitary		60

Comment:

Created On: 01-05-2010 Updated On: 10-08-2019 Review Status: APPROVED