Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WN638

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LIPPOLD, RON	Phone #
Mailing Address: 6441 US 45 S	
City: FOND DU LAC	State: WI — Zip Code: 54935
County: Winnebago	Co. Permit #: — Notification #: 35361156 — Completed: 12-28-2009
Well Constructor (Business Name): WAGNER BROTHERS WELL DRILLING INC	Lic. #: 654 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Address: W2282 COUNTY HWY WH, MT CALVARY WI 53057-9720	
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 2.5	

1. Well Location

Town of BLACKWOLF				Fire # (if avail.): 6441
Street Address or Road Name and Number: 6441 US HWY 45				
Subdivision Name: —	Lot #: —	Block #: —		
Latitude / Longitude in Decimal Degree (DD): 43.9178 °N -88.4739 °W				Method Code: GCD013
SE NW or Govt Lot #: —	Section: 28	Township: 17 N	Range: 17 E	

2. Well Type New Well
of previous unique well #: — constructed in: —
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of GUN SHOP
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	42
6	42	150

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
	Dual Rotary	
No	Temp. Outer Casing ____in. dia	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P.E. 18.97 STEEL ASTM A53 .280 WALL IPSCO	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method Tremie Pipe - Pumped

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Neat cement grout	Surface	42	12 S

8. Geology

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 16 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		01-12-2010
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MF		01-12-2010

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Collector Sewer - San or Storm		60
			Sewer - Building Sanitary		30

Comment:

Created On: 04-19-2010 Updated On: 10-18-2019 Review Status: APPROVED