

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WO597		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LOREN ULNESS						Phone # (262)965-4242		1. Well Location				Fire # (if avail.)			
Mailing Address 3635 CR J						Town of LIBERTY									
City VALDERS						State WI		Zip Code 54245				Street Address or Road Name and Number 3635 CR J			
County Manitowoc		Co. Permit #		Notification # 34895893		Completed 11-09-2009		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) VAN DE YACHT BILL WTR WELL & SPECIA				Lic. # 4462		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0534 °N -87.8793 °W				Method Code GCD013	
Address 3671 MONROE RD DE PERE WI 54115-9711				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 4 18 N 22 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
Hicap Permanent Well #				Common Well #		Specific Capacity 2									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				8. Geology				
9 Surface 61			Yes Rotary - Mud Circulation No				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)				
6 61 142			No Rotary - Air Yes				- - C - Clay				Surface 9				
			No Rotary - Air & Foam No				- - L - Limestone/Dolomite				9 142				
			No Drill-Through Casing Hammer												
			No Reverse Rotary												
			No Cable-tool Bit ___ in. dia... No												
			Dual Rotary												
			No Temp. Outer Casing ___ in. dia												
			No Removed? ___ depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is	
6		new pln end blk steel welded 18.97 .280 a53 wheatland				Surface		61		40 ft. below ground surface				12 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes	
										Pumping level 80 ft. below surface Pumping at 80 GP M for 1 Hrs. Pumping Method ?					
7. Grout or Other Sealing Material															
Method Bradenhead															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
Neat cement grout				Surface		61		17 S							
13. Constructor / Supervisory Driller															
tv				Lic #		Date Signed		11-11-2009							
Drill Rig Operator				Lic or Reg #		Date Signed		11-11-2009							
CV															

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 11-30-2009

Updated On: 10-15-2019

Review Status: APPROVED