

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WO600		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner LEONHARDT, BRAD						Phone # (262)965-4242		1. Well Location				Fire # (if avail.)				
Mailing Address 1412 24TH ST						Town of CATO						Street Address or Road Name and Number				
City TWO RIVERS						State WI		Zip Code 54241				1220 LAKE CATO DR				
County Manitowoc		Co. Permit #		Notification # 34787549		Completed 11-09-2009		Subdivision Name				Lot #		Block #		
Well Constructor (Business Name) VAN DE YACHT BILL WTR WELL & SPECIA				Lic. # 4462		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1141 °N -87.8288 °W				Method Code GCD013		
Address 3671 MONROE RD DE PERE WI 54115-9711				Well Plan Approval #		NW SE		Section 14		Township 19 N		Range 22 E		or Govt Lot #		
Hicap Permanent Well #				Common Well #		Specific Capacity 2				2. Well Type New Well						
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?						
Private, potable				Hicap Potable ?		Construction Type Drilled										
3. Well serves 1 # of																
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
9 Surface 134			Yes Rotary - Mud Circulation				No				- - C -		Clay		Surface 80	
6 134 162			No Rotary - Air				Yes				- - G -		Gravel/Cobbles/Boulders/Stones		80 134	
			No Rotary - Air & Foam				No				- - L -		Limestone/Dolomite		134 162	
			No Drill-Through Casing Hammer													
			No Reverse Rotary													
			No Cable-tool Bit ___ in. dia...				No									
			No Dual Rotary													
			No Temp. Outer Casing ___ in. dia													
			No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														8. Geology		
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		50 ft. below ground surface				11. Well Is		
6		new pln end blk steel welded 18.97 .280 a53 wheatland				Surface		134		10. Pump Test				12 in. above grade		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Developed ? Yes		
										Pumping at 60 GP M for 1 Hrs.				Disinfected ? Yes		
										Pumping Method ?				Capped ? Yes		
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?		
Method																
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes		
Drill mud and cuttings				Surface		134										
13. Constructor / Supervisory Driller								Lic #		Date Signed						
tv										11-11-2009						
Drill Rig Operator								Lic or Reg #		Date Signed						
CV										11-11-2009						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		10
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 12-04-2009

Updated On: 10-15-2019

Review Status: APPROVED