Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WQ970

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WAITE, ADAM	Phone #: (414)870-1800
Mailing Address: 2603 W OAKLAND AVE	
City: MILWAUKEE	State: WI — Zip Code: 53211
County: Sawyer	Co. Permit #:
Notification #: 41961471	Completed: 10-19-2011
Well Constructor (Business Name): BUTTERFIELD ROSCOE WELL & PUMP INC	Lic. #: 6102
Facility ID # (Public Wells):	
Address: 16197 W STATE RD 77 HAYWARD WI 54843	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 7.5	

1. Well Location

Town of HUNTER	Fire # (if avail.): 8301
Street Address or Road Name and Number: WOODLAND DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9349 °N -91.1769 °W	Method Code: GCD013

SE	NE	Section	Township	Range
or Govt Lot #		24	40 N	7 W

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: NOT COMPLIANT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	56

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND, GRAVEL	Surface	10
-	-	Z	-	GRAVEL, CLAY	10	26
-	A	X	M	SAND, CLAY, SILT, COARSE GRAVEL	26	48
-	A	G	S	SAND, COARSE GRAVEL	48	56

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL WELDED 18.97#/FT ASTM A53B IPSCO	Surface	53
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL 18 SLOT	53	56

7. Grout or Other Sealing Material

Method MOUNDED AROUND PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface		

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 9 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
SH		10-24-2011
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		30

Comment: SEPTIC/SEWER NOT IN

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	10/19/2011	I'M THE PUMP INSTALLER TOO

Created On: 11-15-2011 Updated On: 06-24-2020 Review Status: