

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WS059		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BILL SCHOENECKER CONST, JACKLI						Phone # (262)689-5453		1. Well Location				Fire # (if avail.)			
Mailing Address N5116 CO RD U						Town of WAYNE						Street Address or Road Name and Number			
City HARTFORD						State WI		Zip Code 53027				5141 WILDLIFE VIEW CT			
County Washington		Co. Permit #		Notification # 46790293		Completed 01-25-2013		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name)				Lic. # 436		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code	
MICHAEL G HARTMAN										43.52 °N -88.2926 °W				GCD013	
Address MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218				Well Plan Approval #		NE SW		Section 12		Township 12 N		Range 18 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		2. Well Type New Well						of previous unique well #		constructed in	
						Reason for replaced or reconstructed well ?						NEW CONSTRUCTION			
3. Well serves 1 # of				Hicap Well ? No		Construction Type Drilled									
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		44											
6		44		185		Rotary - Mud Circulation				No					
						Yes Rotary - Air									
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit ___ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - C G				STONEY CLAY				Surface		10					
- - Y -				SAND, GRAVEL				10		35					
- - L -				LIMESTONE				35		185					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		.280 A53 GR B WHEATLAND STEEL WELDED				Surface		45							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
PORTLAND CEMENT GROUT				Surface		44		14 S							
9. Static Water Level															
40 ft. below ground surface															
10. Pump Test															
Pumping level 80 ft. below surface															
Pumping at 25 GP for 4 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
NO WELL															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
MH										01-27-2013					
Drill Rig Operator								Lic or Reg #		Date Signed					
MH										01-27-2013					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Foundation Drain to Clearwater		16
Building Overhang		15	Sewer - Building Sanitary		50
Clearwater Sump		20	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-25-2013

Updated On: 07-08-2019

Review Status: