Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WS059

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BILL SCHOENECKER CONST, JACKLI			Phone #: (262)689-5453
Mailing Address: N5116 CO RD U			
City: HARTFORD	State: WI	Zip Code: 53027	
County: Washington	Co. Permit #:	Notification #: 46790293	Completed: 01-25-2013

1. Well Location

Town of WAYNE

Fire # (if avail.):

Street Address or Road Name and Number: 5141 WILDLIFE VIEW CT

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): MICHAEL G HARTMAN	Lic. #: 436	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 43.52 °N -88.2926 °W
Address: MICHAEL HARTMAN WELL DRLG & PUMP I NORTH LAKE WI 53064-0218		Well Plan Approval #:	Method Code: GCD013
		Approval Date (mm-dd-yyyy):	NE SW / or Govt Lot #: Section: 12 Township: 12 N Range: 18 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NEW CONSTRUCTION

Hicap Permanent Well #	Common Well #	Specific Capacity: 0.6

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	44
6	44	185

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	G	STONEY CLAY	Surface	10
-	-	Y	-	SAND, GRAVEL	10	35
-	-	L	-	LIMESTONE	35	185

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	.280 A53 GR B WHEATLAND STEEL WELDED	Surface	45
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 25 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT GROUT	Surface	44	14 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NO WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
MH		01-27-2013
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MH		01-27-2013

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Foundation Drain to Clearwater		16
Building Overhang		15	Sewer - Building Sanitary		50
Clearwater Sump		20	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-25-2013 Updated On: 07-08-2019 Review Status: