Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WS281

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MCNALLON, JOHN	Phone #: (507)226-4343
Mailing Address: 518 WHITEWATER WAY	
City: ELGIN	State: MN Zip Code: 55932
County: Burnett	Co. Permit #:
Notification #: 41661612	Completed: 09-13-2011
Well Constructor (Business Name): ROGER E BEECROFT	Lic. #: 182
Facility ID # (Public Wells):	
Address: ROGERS WELL DRILLING SHELL LAKE WI 54871-9801	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.1	

1. Well Location

Town of SCOTT

Fire # (if avail.):

Street Address or Road Name and Number: 29313 HONKER HOLLOW

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 45.9759 °N -92.079 °W

Method Code: GCD013

NW SE or Govt Lot #	Section	Township	Range
	3	40 N	14 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	179

Upper Enlarged Drillhole

Yes

Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

Lower Open Bedrock

No

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	36
-	-	C	S	SANDY CLAY	36	52
-	-	S	-	SAND	52	80
-	-	Z	-	GRAVEL & CLAY	80	166
-	-	S	-	SAND	166	179

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC SDR17 EAGLE SOLVENT WELD FORMATION STABILIZER	Surface	175
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	P.S. S.S. 10	175	179

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 150 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
E-Z SEAL	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		09-19-2011
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JB		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		15
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 10-04-2011 Updated On: 06-30-2020 Review Status: