

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WS281		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MCNALLON, JOHN						Phone # (507)226-4343		1. Well Location				Fire # (if avail.)					
Mailing Address 518 WHITEWATER WAY						Town of SCOTT						Street Address or Road Name and Number					
City ELGIN						State MN		Zip Code 55932				29313 HONKER HOLLOW					
County Burnett		Co. Permit #		Notification # 41661612		Completed 09-13-2011		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) ROGER E BEECROFT				Lic. # 182		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.9759 °N -92.079 °W				Method Code GCD013			
Address ROGERS WELL DRILLING SHELL LAKE WI 54871-9801				Well Plan Approval #		NW SE		Section 3		Township 40 N		Range 14 W		or Govt Lot #			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				2. Well Type New Well							
3. Well serves 1 # of				Hicap Well ? No		of previous unique well #						constructed in					
Private, potable				Hicap Property ? No		Reason for replaced or reconstructed well ?						Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
8.75		Surface		179		Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
- - S -				SAND				Surface		36							
- - C S				SANDY CLAY				36		52							
- - S -				SAND				52		80							
- - Z -				GRAVEL & CLAY				80		166							
- - S -				SAND				166		179							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
5		PVC SDR17 EAGLE SOLVENT WELD FORMATION STABILIZER				Surface		175									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		P.S. S.S. 10				175		179									
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
E-Z SEAL				Surface													
9. Static Water Level																	
28 ft. below ground surface																	
10. Pump Test																	
Pumping level 150 ft. below surface																	
Pumping at 15 GP M for 1 Hrs.																	
Pumping Method ?																	
11. Well Is																	
18 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed?																	
13. Constructor / Supervisory Driller								Lic #		Date Signed							
RB										09-19-2011							
Drill Rig Operator								Lic or Reg #		Date Signed							
JB																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		15
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 10-04-2011

Updated On: 06-30-2020

Review Status: