

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WS283		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FOSS, TOM						Phone # (715)645-0823		1. Well Location				Fire # (if avail.)			
Mailing Address W7748 RAINBOW DR						Town of BASHAW						W7748			
City SPOONER						State WI		Zip Code 54801				Street Address or Road Name and Number RAINBOW DR			
County Washburn		Co. Permit #		Notification # 41626553		Completed 09-01-2011		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) ROGER E BEECROFT				Lic. # 182		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8064 °N -91.9307 °W				Method Code GCD013	
Address ROGERS WELL DRILLING SHELL LAKE WI 54871-9801				Well Plan Approval #		SE NE		Section 2		Township 38 N		Range 13 W		or Govt Lot #	
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 1.7				2. Well Type Replacement			
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ? DRY POINT				Construction Type Drilled					
3. Well serves 1 # of Private, potable				Heat Exchange ___ # of drillholes		Hicap Well ? No				Hicap Property ? No					
Hicap Potable ?				Hicap Well ? No		Hicap Property ? No				Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		60		Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes - - S - Type, Caving/Noncaving, Color, Hardness, etc... SAND From (ft.) Surface To (ft.) 60					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
5		SDR17 PVC CASING CEMENT SOLVENT WELD FORMATION STABILIZER				Surface		56		9. Static Water Level 30 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test					
5		S.S. SCREEN 10 SLOT				56		60		Pumping level 48 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ?					
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		11. Well Is					
EZ SEAL				Surface						18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
RB										Lic #		Date Signed			
Drill Rig Operator										Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		20
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 10-04-2011

Updated On: 06-26-2020

Review Status: