

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WS285		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner HOVER, PAT					Phone # (715)205-1260		1. Well Location				Fire # (if avail.)	
Mailing Address 176 S 14TH ST							Town of CRYSTAL				W4890	
City BARRON					State WI		Zip Code 54812				Street Address or Road Name and Number CO RD A	
County Washburn		Co. Permit #		Notification # 41700894		Completed 09-16-2011		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) ROGER E BEECROFT				Lic. # 182		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8584 °N -91.7831 °W			Method Code GCD013	
Address ROGERS WELL DRILLING SHELL LAKE WI 54871-9801				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 18 39 N 11 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)			Lower Open Bedrock			
8.75		Surface		60								
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
- - S -		SAND				Surface		10				
- - Y -		SAND & GRAVEL				10		60				
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)				
5		SDR17 PVC CASING CEMENT SOLVENT WELD				Surface		56				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)				
5		10 SLOT S.S. SCREEN				56		60				
7. Grout or Other Sealing Material												
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement EZ SEAL Surface												
9. Static Water Level 17 ft. below ground surface												
10. Pump Test Pumping level 50 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?												
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes												
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?												
13. Constructor / Supervisory Driller						Lic #		Date Signed				
RB												
Drill Rig Operator						Lic or Reg #		Date Signed				
JB								09-19-2011				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		30

Comment:

Created On: 10-04-2011

Updated On: 06-26-2020

Review Status: