Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WS558

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BASSETT, MARIE			Phone #: (715)635-3385
Mailing Address: 25622 ROLLING GREEN RD			
City: SPOONER	State: WI	Zip Code: 54801	
County: Burnett	Co. Permit #:	Notification #: 44862548	Completed: 07-04-2012

Well Constructor (Business Name): DWAYNE HAYEN	Lic. #: 604	Facility ID # (Public Wells):	
Address: HAYEN PUMP & WELL SARONA WI 54870		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of RUSK

Fire # (if avail.): 25622

Street Address or Road Name and Number: ROLLING GREEN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.8445 °N	-92.0762 °W			GCD013
SE SE or Govt Lot #	Section: 22	Township: 39 N	Range: 14 W	

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD PIT POINT

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	60

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	10
-	-	S	-	SAND	10	55
-	A	S	-	COARSE SAND	55	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PE BLACK 14.62 ASTM A53B ISPCO USA	Surface	56
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	SS 12 SLOT	56	60

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
26 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 10 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DH		07-10-2012
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120
Building Overhang		45
Shoreline/Pool		80
Sewer - Building Sanitary		50
Septic or Holding, or POWTS Tank		100

Comment:

Created On: 07-24-2012 Updated On: 06-30-2020 Review Status: