Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WS561

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: JOHNSON, SY	Phone #: (715)556-2350
Mailing Address: N3243 DEEP PATH RD	
City: SARONA	State: WI — Zip Code: 54870
County: Washburn	Co. Permit #:
Notification #: 45066249	Completed: 08-11-2012
Well Constructor (Business Name): DWAYNE HAYEN	Lic. #: 604
Facility ID # (Public Wells):	
Address: HAYEN PUMP & WELL SARONA WI 54870	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 4	

1. Well Location

Town of MADGE				Fire # (if avail.): N3243
Street Address or Road Name and Number: DEEP PATH RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.7511 °N -91.7703 °W				Method Code: GCD013
NE	NE	Section: 30	Township: 38 N	Range: 11 W
or Govt Lot #				

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	140

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	9
-	-	Z	P	HARDPAN CLAY & GRAVEL ROCK	9	50
-	-	S	-	SAND	50	62
-	-	Z	-	CLAY & GRAVEL	62	100
-	-	X	U	DIRTY SAND & CLAY	100	138
-	E	S	-	CLEAN SAND	138	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PE BLACK 14.62 ASTM A53B IPSCO USA	Surface	140
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENT	Surface		

9. Static Water Level
53 ft. below ground surface

10. Pump Test
Pumping level 57 ft. below surface
Pumping at 16 GP for 8 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DH		08-17-2012
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80
Building Overhang		45
Shoreline/Pool		150
Sewer - Building Sanitary		70
Septic or Holding, or POWTS Tank		90

Comment: SEWER NOT IN YET

Created On: 09-05-2012 Updated On: 06-26-2020 Review Status: