

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WS561		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner JOHNSON, SY						Phone # (715)556-2350		1. Well Location				Fire # (if avail.)		
Mailing Address N3243 DEEP PATH RD						Town of MADGE						N3243		
City SARONA						State WI		Zip Code 54870				Street Address or Road Name and Number DEEP PATH RD		
County Washburn		Co. Permit #		Notification # 45066249		Completed 08-11-2012		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) DWAYNE HAYEN				Lic. # 604		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.7511 °N -91.7703 °W			Method Code GCD013	
Address HAYEN PUMP & WELL SARONA WI 54870				Well Plan Approval #		NE NE		Section 30		Township 38 N		Range 11 W		
						or Govt Lot #								
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 4		2. Well Type New Well				
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?								
Heat Exchange ___ # of drillholes				Hicap Well ? No		Construction Type Drilled								
3. Well serves 1 # of Private, potable														
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
5		Surface		140		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
-	-	Y	-	SAND & GRAVEL				Surface		9				
-	-	Z	P	HARDPAN CLAY & GRAVEL ROCK				9		50				
-	-	S	-	SAND				50		62				
-	-	Z	-	CLAY & GRAVEL				62		100				
-	-	X	U	DIRTY SAND & CLAY				100		138				
-	E	S	-	CLEAN SAND				138		140				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
5		PE BLACK 14.62 ASTM A53B IPSCO USA				Surface		140						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENT				Surface										
9. Static Water Level														
53 ft. below ground surface														
10. Pump Test														
Pumping level 57 ft. below surface														
Pumping at 16 GP for 8 Hrs.														
Pumping Method ?														
11. Well Is														
15 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
Lic #				Date Signed										
DH				08-17-2012										
Drill Rig Operator				Lic or Reg #										
				Date Signed										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Shoreline/Pool		150
Building Overhang		45	Sewer - Building Sanitary		70
			Septic or Holding, or POWTS Tank		90

Comment: SEWER NOT IN YET

Created On: 09-05-2012

Updated On: 06-26-2020

Review Status: