Well Construction Report
WISCONSIN UNIQUE WELL NUMBER WS562

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MUSCH, JEAN	Phone #: (715)635-6858
Mailing Address: W7776 DUNN LAKE RD	
City: SPOONER	State: WI — Zip Code: 54801
County: Washburn	Co. Permit #:
Notification #: 46445929	Completed: 11-28-2012
Well Constructor (Business Name): DWAYNE HAYEN	Lic. #: 604
Facility ID # (Public Wells):	
Address: HAYEN PUMP & WELL SARONA WI 54870	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 5	

1. Well Location

Town of CASEY	Fire # (if avail.): W7776
Street Address or Road Name and Number: DUNN LAKE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9287 °N -91.9343 °W	Method Code: GCD013
SE SE or Govt Lot #:	Section: 23 — Township: 40 N — Range: 13 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: OLD SAND POINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	37

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	18
-	-	Y	-	SAND & GRAVEL	18	24
-	-	G	-	BIG GRAVEL	24	37

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PE BLACK 14.62 ASTM A53B IPSCO USA	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	SS 12 SLOT	33	37

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 17 ft. below surface

Pumping at 15 GP for 1 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DH		12-06-2012
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100
Building Overhang		16
Shoreline/Pool		70
Sewer - Building Sanitary		60
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-10-2013 Updated On: 06-26-2020 Review Status: