

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WS562		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MUSCH, JEAN						Phone # (715)635-6858		1. Well Location				Fire # (if avail.)	
Mailing Address W7776 DUNN LAKE RD						Town of CASEY						W7776	
City SPOONER						State WI		Zip Code 54801				Street Address or Road Name and Number	
DUNN LAKE RD						Subdivision Name				Lot #		Block #	
County Washburn		Co. Permit #		Notification # 46445929		Completed 11-28-2012		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) DWAYNE HAYEN				Lic. # 604		Facility ID # (Public Wells)				45.9287 °N -91.9343 °W		GCD013	
Address HAYEN PUMP & WELL SARONA WI 54870				Well Plan Approval #		SE SE		Section 23		Township 40 N		Range 13 W	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 5		2. Well Type Replacement				of previous unique well # constructed in			
Reason for replaced or reconstructed well ?		OLD SAND POINT											
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
5		Surface		37		Rotary - Mud Circulation							
						Rotary - Air							
						Rotary - Air & Foam							
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ___ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ___ in. dia							
						Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
- - S -				SAND				Surface		18			
- - Y -				SAND & GRAVEL				18		24			
- - G -				BIG GRAVEL				24		37			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
5		PE BLACK 14.62 ASTM A53B IPSCO USA				Surface		33		14 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
3		SS 12 SLOT				33		37		15 in. above grade			
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test			
				Surface						Pumping level 17 ft. below surface			
										Pumping at 15 GP for 1 Hrs.			
										Pumping Method ?			
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
DH				Lic #		Date Signed		12-06-2012					
Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Shoreline/Pool		70
Building Overhang		16	Sewer - Building Sanitary		60
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-10-2013

Updated On: 06-26-2020

Review Status: