

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				WS571		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner BRECHT, WAYNE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address W11061 N LETOURNEAU								Town of FLAMBEAU					
City PARK FALLS						State WI		Zip Code 54552					
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #	
Price				40947996		06-30-2011						Block #	
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
JEFFREY J HOLT				5891				45.8241 °N -90.626 °W				GCD013	
Address HOLT WELL DRILLING PARK FALLS WI 54552-1390				Well Plan Approval #		NW NE		Section		Township		Range	
				Approval Date (mm-dd-yyyy)		or Govt Lot #		33		39 N		2 W	
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type Replacement					
						0.3		of previous unique well # constructed in					
Reason for replaced or reconstructed well ?								PUMPED SAND & CLAY					
3. Well serves 1 # of				Hicap Well ?		No		Construction Type Drilled					
Private, potable				Hicap Property ?		No							
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
6		Surface		75						Geology Codes			
						Rotary - Mud Circulation				Type, Caving/Noncaving, Color, Hardness, etc...			
						Rotary - Air				From (ft.)			
						Rotary - Air & Foam				To (ft.)			
						Drill-Through Casing Hammer				- - C - CLAY			
						Reverse Rotary				Surface			
						Cable-tool Bit ___ in. dia...				6			
						Dual Rotary				- - G P GRAVEL HARDPAN			
						Temp. Outer Casing ___ in. dia				6			
						Removed? ___ depth ft. (If NO explain on back side)				30			
										- - S C SAND & CLAY			
										30			
										- - Y - SAND & GRAVEL			
										65			
										75			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		ASTM A53B PE IPSCO				Surface		72		17 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
5		STAINLESS 15				72		75		18 in. above grade			
7. Grout or Other Sealing Material													
Method MOUND													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test			
GRANULAR BENTONITE				Surface						Developed ? Yes			
										Disinfected ? Yes			
										Capped ? Yes			
										Pumping level 50 ft. below surface			
										Pumping at 10 GP for 10 Hrs.			
										Pumping Method ?			
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
JJH													
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Building Overhang		15
			Septic or Holding, or POWTS Tank		25

Comment:

Created On: 08-02-2011

Updated On: 06-19-2020

Review Status: